

# PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, KAITHAL



Website :- <https://phedharyana.gov.in/>

Memo No.- 1133

Date:- 08/08/2024

Subject : **Bacteriological Examination Report of Water Sample**

Sample ID: KTL/02586/8/2024		Sample Details	Date & Time
Sample Classification: Private		Collected By	Pawan Sharma,8607435651
Sender: Mothers Pride Public School		Collection Date	06/08/2024 at 10:12
Location :- , Behind Housing Board Colony Cheeka		Received at lab	06/08/2024 at 11:23
Latitude :- 76.325819 Longitude :- 30.052974		Tested at Lab	08/08/2024

## Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C, 2017

### Remarks :-

- \* The Results Given above are related to the sample as received and tested in KAITHAL lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"



SUBHASH CHANDER, CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
DISTRICT WATER TESTING LABORATORY KAITHAL  
email:-chemist.kaithal@phedharyana.gov.in

-----End of Report-----